



# Certificate of Compliance

This certificate is issued for the following:

System Designation:	HI-FOG GPU Water Mist System for the Protection of Combustion Turbines, Machinery Spaces, and Special Hazard Machinery Spaces in Enclosures with Volumes up to, and Including, 53,000 ft <sup>3</sup> (1,500 m <sup>3</sup> ) and a Maximum Height of 32.8 ft (10.0 m).
Design, Installation, Operation and Maintenance Manual:	HI-FOG® Systems (GPU) for Total Compartment Protection of Combustion Turbines, Machinery Spaces, and Special Hazard Machinery Spaces With Volumes up to, and Including 1500 m <sup>3</sup> (53000 ft <sup>3</sup> ), Design, Installation, Operation and Maintenance Manual, Document Ref: MO/ES/29/DIOM/FM/09, Revision 1.1, Date of Issue: Sept '14

**Prepared for:**

MARIOFF CORPORATION OY  
PLAZA BUSINESS PARK HALO  
AYRITIE 24  
FIN-01510  
VANTAA, FINLAND

**Manufactured at:**

MARIOFF CORPORATION OY  
MOREENITIE 4  
FIN-04250  
KERAVA, FINLAND

FM Approvals Class: 5560

Approval Identification: 3024528      Approval Granted: December 19, 2014

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com) or [www.roofnav.com](http://www.roofnav.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'Richard B. Dunne', written over a horizontal line.

Richard B. Dunne  
Manager – Fire Protection Group  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*